



Collier Youth Services
BELONGING • DIGNITY • HOPE

June 27, 2022

Collier School
160 Conover Road
Wickatunk, NJ 07765

Dear Collier Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Collier School tested our school's drinking water for lead.

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we conducted testing on all drinking water and food preparation outlets. **Of the 27 samples taken, we are very pleased to report that all tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).**

The original report AGRA_Analytical_Rpt220413037_20220511164947 showed a false positive for the KT Serv Sink. This was retested on 5/20/2022 and shows in report AGRA_Analytical_Rpt220512035_20220606115442 that the one sink is within normal parameters.

A copy of all test results are available below, and additional documentation is also available for inspection by the public, including students, teachers, other school personnel, and parents on campus. If you have any questions or concerns, please feel free to contact me at 732-946-4771 x350.

Sincerely,

William Colbert
Facilities Manager, Operations and Maintenance

SERVING YOUTH AND FAMILIES SINCE 1927
SPONSORED BY THE SISTERS OF THE GOOD SHEPHERD

160 Conover Road, P.O. Box 300, Wickatunk, NJ 07765 Tel 732.946.4771 Fax 732.946.3519 www.collieryouthservices.org



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 10, 2022
Client: Collier School
Address: 160 Conover Rd
Wickatunk, NJ 07765

Analytical Results

PWSID#:

Project Location:

Sample Matrix:	Drinking Water	Lab Sample Number:	220413036-001							
Sample Location:	Water Cooler by Gym	Customer Sample Number:								
Sampled By:	B. Ellmer									
Sample Date/Time:	4/22/2022 9:28									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	2.52	µg/L	15	5/3/2022	15:14	JGW	2	1	

Sample Matrix:	Drinking Water	Lab Sample Number:	220413036-002							
Sample Location:	Faculty Rm Sink	Customer Sample Number:								
Sampled By:	B. Ellmer									
Sample Date/Time:	4/22/2022 9:30									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	2.73	µg/L	15	5/3/2022	15:20	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220413036-003							
Sample Location: Water Cooler by Nurse		Customer Sample Number:							
Sampled By: B. Ellmer									
Sample Date/Time: 4/22/2022 9:31									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.41	µg/L	15	5/3/2022	14:47	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220413036-004							
Sample Location: Nurse's Office Sink		Customer Sample Number:							
Sampled By: B. Ellmer									
Sample Date/Time: 4/22/2022 9:33									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.28	µg/L	15	5/3/2022	15:25	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220413036-005							
Sample Location: Water Cooler by Rm 5		Customer Sample Number:							
Sampled By: B. Ellmer									
Sample Date/Time: 4/22/2022 9:37									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.26	µg/L	15	5/3/2022	15:31	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220413036-006							
Sample Location: Bottle Filler by Rm 5		Customer Sample Number:							
Sampled By: B. Ellmer									
Sample Date/Time: 4/22/2022 9:36									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.93	µg/L	15	5/3/2022	15:37	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220413036-007							
Sample Location: Field Blank		Customer Sample Number:							
Sampled By: B. Ellmer									
Sample Date/Time: 4/22/2022 9:28									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/3/2022	15:42	JGW	2	1

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Laboratory Manager

May 10, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220413036
220413036

Customer Name: Collier School

Location:

Address: 160 Conover Rd

Wickatunk, NJ, 07765

Customer Contact: Christine DeCuore

Phone: Work/Cell 732-946-4771 x122 /

Agra Environmental Services

90 % West Blackwell Street

Dover, NJ 07801

Phone: (973) 989-0010

Fax: (973) 989-0156

Asc./HCl Vials pH: -
HCl Vials pH:
Na₂S₂O₈ Cl:
HNO₃ pH: 2.2
H₂SO₄ pH:
NaOH pH:
unpreserved
other
other

Page 1 of 1

P - Pool L - Lake

SL - Sludge

WW/NPW - Wastewater

RAW-GW - DW RAW GW

GW - Ground Water

Project: High School Pb

Collection

PWSID#

Comp

Grab

of Bottles

Matrix

Preservative

for laboratory use only

Field Analysis

Cl₂
or
PO₄

Sample ID Location Date Time

220413036-001 WC by Gym 4/22/09 0928

220413036-002 Faculty Rm Sink 4/22/09 0930

220413036-003 WC by Nurse 4/23/09 0931

220413036-004 Nurse Office Sink 4/23/09 0933

220413036-005 WC by Rm 5 4/23/09 0937

220413036-006 Bottle Filler by Rm 5 4/23/09 0939

220413036-007 Field Blank 4/23/09 0928

ANALYSIS REQUESTED

Lead-1st Draw

Lead-1st Draw

Lead-1st Draw

Lead-1st Draw

Lead-1st Draw

Lead-1st Draw

Lead-1st Draw

Sampled By (name/company):

B. Ellmers/Agra

Are these samples for compliance? (circle one): Yes or No

No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab:

Reporting Requirements (Check Box):

Standard

Reduced

Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:

Date: 4/22/09

Time: 11:50

Received By:

Date: 4/22/09

Time: 11:50

Relinquished By:

Date: 4/28/09

Time: 11:39

Received By:

Date: 4/28/09

Time: 11:40

Relinquished By:

Date:

Time:

Received By:

Date:

Time:

Relinquished By:

Date:

Time:

Received By:

Date:

Time:

Comments: *in water last run*
4/21/22/600
pH + turb @ Marlboro 4/28/09

Date Faxed: _____
 Invoice Number: _____

Is sample known to be hazardous? (circle one)
 Yes or No



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 11, 2022
Client: Collier School
Address: 160 Conover Rd
Wickatunk, NJ 07765

Analytical Results

PWSID#:
Project Location:

Table with sample details: Sample Matrix (Drinking Water), Sample Location (Water Cooler Back Area), Sampled By (B. Ellmer), Sample Date/Time (4/22/2022 9:13), Lab Sample Number (220413037-001), Customer Sample Number.

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Row: Lead-1st Draw, SM3113B, < 2.00, µg/L, 15, 5/4/2022, 12:40, JGW, 2, 1.

Table with sample details: Sample Matrix (Drinking Water), Sample Location (Water Cooler 2nd Fl Hall), Sampled By (B. Ellmer), Sample Date/Time (4/22/2022 9:17), Lab Sample Number (220413037-002), Customer Sample Number.

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Row: Lead-1st Draw, SM3113B, < 2.00, µg/L, 15, 5/4/2022, 13:07, JGW, 2, 1.



Environmental and Laboratory Services

Dover Location:
 90 1/2 West Blackwell St., Dover, NJ 07801
 Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
 8A Railroad Ave, Marlboro, NJ 07746
 Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 10, 2022
 Client: Collier School
 Address: 160 Conover Rd
 Wickatunk, NJ 07765

Analytical Results

PWSID#:
 Project Location:

Sample Matrix: Drinking Water		Lab Sample Number: 220413038-001								
Sample Location: Water Cooler		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 4/22/2022 9:54										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	6.27	µg/L	15	5/3/2022	20:08	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220413038-002								
Sample Location: Sink		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 4/22/2022 9:52										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	2.37	µg/L	15	5/3/2022	20:46	JGW	2	1	

Sample Matrix:	Drinking Water	Lab Sample Number:	220413038-003
Sample Location:	Field Blank	Customer Sample Number:	
Sampled By:	B. Ellmer		
Sample Date/Time:	4/22/2022 9:52		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/3/2022	20:52	JGW	2	1

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Laboratory Manager

May 10, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

22041308
220413038

Customer Name: Collier School

Location:

Address: 160 Conover Rd

Wickatunk, NJ, 07765

Customer Contact: Christine DelCuore

Phone: Work/Cell 732-946-4771 x122 /

Agra Environmental Services

90 1/2 West Blackwell Street

Dover, NJ 07801

Phone: (973) 989-0010

Fax: (973) 989-0156

#	Asc./HCl Vials	pH:
#	HCl Vials	pH:
#	Na ₂ S ₂ O ₈	Cl ₂ :
#	HNO ₃ (Bottle)	pH: 22
#	H ₂ SO ₄	pH:
#	NaOH	pH:
#	unpreserved	
#	other	
#	other	

Page 1 of 1

P - Pool L - Lake

SL - Sludge

WW/NPW - Wastewater

RAW-GW - DW RAW GW

GW - Ground Water

DW - Drinking water

Project: Solar Bldg Pb

Collection PWSID#

Comp

Matrix

of Bottles

Preservative

for laboratory use only

Field Analysis

Sample ID Location

Date Time

ANALYSIS REQUESTED

Lead-1st Draw

pH / Temp

Cl₂
or
PO₄

220413038-001 Water Cooler

4/22/22 0954

HNO₃

Lead-1st Draw

220413038-002 Sink

0952

HNO₃

Lead-1st Draw

220413038-003 Field Blank

0952

HNO₃

Lead-1st Draw

Sampled By (name/company):

B. Ellmes

Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab:

Reporting Requirements (Check Box):

Standard

Reduced

Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:

Date: 4/22/22 Time: 1150

Received By: *Christine DelCuore*

Date: 4/21/22 Time: 1600

Comments: water last run

Relinquished By:

Date: 4/28/22 Time: 1139

Received By: *Shawny*

Date: 4/21/22 Time: 1446

PH + turb @ Marlboro

4/20/22

Relinquished By:

Date: Time:

Received By:

Date: Time:

Date Faxed Invoice Number

Relinquished By:

Date: Time:

Received By:

Date: Time:

Is sample known to be hazardous? (circle one)

Yes or No



Environmental and Laboratory Services

Dover Location:
 90 1/2 West Blackwell St., Dover, NJ 07801
 Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
 8A Railroad Ave, Marlboro, NJ 07746
 Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 10, 2022
 Client: Collier School
 Address: 160 Conover Rd
 Wickatunk, NJ 07765

Analytical Results

PWSID#:

Project Location:

Sample Matrix: Drinking Water		Lab Sample Number: 220413039-001								
Sample Location: Faculty Rm Sink		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 4/22/2022 9:42										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/3/2022	20:57	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220413039-002								
Sample Location: Field Blank		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 4/22/2022 9:42										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	2.13	µg/L	15	5/3/2022	21:03	JGW	2	1	

Collier School

NJ Lab ID# 14013 (Dover)

NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.

Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.

All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan Van Veen

Susan VanVeen, Laboratory Manager

May 10, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220413039

Customer Name: Collier School

Location:

Address: 160 Conover Rd

Wickatunk, NJ, 07765

Customer Contact: Christine DelCuore

Phone: Work/Cell 732-946-4771 x122 /

Agra Environmental Services

90 1/2 West Blackwell Street

Dover, NJ 07801

Phone: (973) 989-0010

Fax: (973) 989-0156

- # Asc/HCl Vials pH:
- # HCl Vials pH:
- # Na2SiO3 Cl2:
- # HNO3, Unpreserved pH: *FL*
- # H2SO4 pH:
- # NaOH pH:
- # unpreserved
- # other

Page 1 of 1

P - Pool L - Lake

SL - Sludge

WW/NPW - Wastewater

RAW-GW - DW RAW GW

GW - Ground Water

DW - Drinking water

Project: SS Annex Pb

Collection PWSID#

for laboratory use only

Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220413039-001	Faculty Rm Sink	4/22/22	0942	X		DW	1	HNO3	Lead-1st Draw		
220413039-002	Field Blank	4/22/22	0942	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company):

B. Ellmes/Agra

Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab:

Reporting Requirements (Check Box):

Standard

NJ

Reduced

Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:

Date: 4/24/22

Time: 1150

Received By:

Date: 4/22/22

Time: 1150

Comments: WATER LAST

Relinquished By:

Date: 4/28/22

Time: 1137

Received By:

Date: 4/22/22

Time: 1150

Comments: Run 4/21/22 1400

Relinquished By:

Date:

Time:

Received By:

Date:

Time:

Comments: PH + turb @ Marlboro 4/21/22

Relinquished By:

Date:

Time:

Received By:

Date:

Time:

Comments: PH + turb @ Marlboro 4/21/22

Relinquished By:

Date:

Time:

Received By:

Date:

Time:

Comments: PH + turb @ Marlboro 4/21/22

Is sample known to be hazardous? (circle one)

Yes or No

Page 3 of 3



Environmental and Laboratory Services

Dover Location:

90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:

8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 10, 2022
Client: Collier School
Address: 160 Conover Rd
Wickatunk, NJ 07765

Analytical Results

PWSID#:
Project Location:

Table with sample details: Sample Matrix (Drinking Water), Sample Location (2nd Fl Sink), Sampled By (B. Ellmer), Sample Date/Time (4/22/2022 9:58), Lab Sample Number (220413040-001), Customer Sample Number.

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Row 1: Lead-1st Draw, SM3113B, 4.21, ug/L, 15, 5/3/2022, 15:48, JGW, 2, 1.

Table with sample details: Sample Matrix (Drinking Water), Sample Location (1st FL Kitchen), Sampled By (B. Ellmer), Sample Date/Time (4/22/2022 10:01), Lab Sample Number (220413040-002), Customer Sample Number.

Table with 10 columns: Parameters, Method, Results, Units, NJDEP Limit, Date Analyzed, Time Analyzed, Analyst, Reporting Limit, Dilution Factor. Row 1: Lead-1st Draw, SM3113B, 4.59, ug/L, 15, 5/3/2022, 16:10, JGW, 2, 1.

Sample Matrix: Drinking Water		Lab Sample Number: 220413040-003								
Sample Location: Water Cooler Back Area		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 4/22/2022 10:03										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/3/2022	16:15	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220413040-004								
Sample Location: Bottle Filler Back Area		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 4/22/2022 10:04										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/3/2022	16:21	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220413040-005								
Sample Location: Field Blank		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 4/22/2022 9:58										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/3/2022	16:26	JGW	2	1	

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan Van Veen
 Susan VanVeen, Laboratory Manager

May 10, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220413040
220413040

Customer Name: Collier School
Location: 160 Conover Rd
Address: Wickatunk, NJ, 07765
Customer Contact: Christine DelCuore
Phone: Work/Cell 732-946-4771 x122 /

Agra Environmental Services
90 1/2 West Blackwell Street
Dover, NJ 07801
Phone: (973) 989-0010
Fax: (973) 989-0156

Asc./HCl Vials pH:
HCl Vials pH:
Na-SrO₃ Cl₂:
HNO₃ 250ml pH:
H₂SO₄ pH:
NaOH pH:
unpreserved
other

Page 1 of 1

Matrix Abbreviations:	DW - Drinking water	GW - Ground Water	RAW-GW - DW RAW GW	WW/NPW - Wastewater	SL - Sludge	P - Pool	L - Lake	Project:	Stars Pb

for laboratory use only

ANALYSIS REQUESTED

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED
220413040-001	2nd FI Sink	4/22/02	0958	X	DW	DW	1	HNO3	Lead-1st Draw
220413040-002	1st FI Kitchen	1003		X	DW	DW	1	HNO3	Lead-1st Draw
220413040-003	Water Cooler Back Area	1003		X	DW	DW	1	HNO3	Lead-1st Draw
220413040-004	Bottle Filler Back Area	1004		X	DW	DW	1	HNO3	Lead-1st Draw
220413040-005	Field Blank	0958		X	DW	DW	1	HNO3	Lead-1st Draw

Field Analysis
pH / Temp
Cl₂
or
PO₄

Sampled By (name/company): B. Ellmers/Agra Are these samples for compliance? (circle one): Yes or **No**

NJDEP Laboratory Certification (Dover, NJ) #14013
NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)
 Relinquished By: [Signature] Date: 4/22/02 Time: 1150
 Relinquished By: [Signature] Date: 4/28/02 Time: 1139
 Relinquished By: [Signature] Date: 4/28/02 Time: 1146
 Relinquished By: [Signature] Date: 4/28/02 Time: 1146

Indicate laboratory location where analysis request was performed
[Redacted]
Cooler Temperature Upon Receipt at lab: [Redacted]

Comments: Water - test run 4/21/02
PH + turb @ Marlboro 4/18/02

Date Faxed: _____ Invoice Number: _____
 Date: _____ Time: _____
 Date: _____ Time: _____
 Date: _____ Time: _____
 Date: _____ Time: _____

Is sample known to be hazardous? (circle one) Yes or No



Environmental and Laboratory Services

Dover Location:
 90 1/2 West Blackwell St., Dover, NJ 07801
 Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
 8A Railroad Ave, Marlboro, NJ 07746
 Phone: (732) 308-3500, Fax (732) 308-3503

Date: June 06, 2022
Client: Collier School
Address: 160 Conover Rd
 Wickatunk, NJ 07765

Analytical Results

PWSID#:
Project Location:

Sample Matrix:	Drinking Water	Lab Sample Number:	220512035-001		
Sample Location:	KT Serv Sink	Customer Sample Number:			
Sampled By:	B. Ellmer				
Sample Date/Time:	5/20/2022 6:07				

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.21	µg/L	15	5/31/2022	13:58	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220512035-002		
Sample Location:	KT Serv Sink	Customer Sample Number:			
Sampled By:	B. Ellmer				
Sample Date/Time:	5/20/2022 6:08				

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead	SM3113B	< 2.00	µg/L	5	5/31/2022	14:04	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220512035-003								
Sample Location: KT Wash Rm Sink 2		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 5/20/2022 6:11										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead-1st Draw	SM3113B	4.85	µg/L	15	5/31/2022	14:09	JGW	2	1	

Sample Matrix: Drinking Water		Lab Sample Number: 220512035-004								
Sample Location: KT Wash Rm Sink 2		Customer Sample Number:								
Sampled By: B. Ellmer										
Sample Date/Time: 5/20/2022 6:12										
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor	
Lead	SM3113B	4.10	µg/L	5	5/31/2022	14:15	JGW	2	1	

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan Van Veen
 Susan VanVeen, Laboratory Manager

June 06, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

220512035

Customer Name: Collier School

Location:

Address: 160 Conover Rd

Wickatunk, NJ, 07765

Customer Contact: Will Colbert

Phone: Work/Cell 732-946-4771 x122 /

Agra Environmental Services

90 1/2 West Blackwell Street

Dover, NJ 07801

Phone: (973) 989-0010

Fax: (973) 989-0156

Asc./HCl Vials pH:
 # HCl Vials pH:
 # Na₂S₂O₈ Cl₂:
 # HNO₃ pH: 4
 # H₂SO₄ pH: 4
 # NaOH pH:
 # unpreserved
 # other

Page 1 of 1

L - Lake

SL - Sludge

WW/NPW - Wastewater

RAW-GW - DW RAW GW

GW - Ground Water

DW - Drinking water

Project: Smith Hall Pb

Collection PWSID#

for laboratory use only

Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂	or	PO ₄
220512035-001	KT Serv Sink	5/20/22	0607	X		DW	1	HNO3	Lead-1st Draw				
220512035-002	KT Serv Sink	5/20/22	0608	X		DW	1	HNO3	Lead - Flush				
220512035-003	KT WashRm Sink 2	5/20/22	0411	X		DW	1	HNO3	Lead-1st Draw				
220512035-004	KT WashRm Sink 2	5/20/22	0412	X		DW	1	HNO3	Lead - Flush				

Sampled By (name/company):

B. Ellmes/Agar

Are these samples for compliance? (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):

Standard

NJ Reduced

Other (Specify)

Cooler Temperature Upon Receipt at lab:

N/A

Indicate laboratory location where analysis request was performed

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:

Date: 5/20/22

Time: 1131

Received By: [Signature]

Date: 5/20/22

Time: 1131

Relinquished By:

Date: 5/20/22

Time: 1011

Received By: [Signature]

Date: 5/25/22

Time: 1014

Relinquished By:

Date: 5/25/22

Time: 1014

Received By: [Signature]

Date: 5/25/22

Time: 1014

Relinquished By:

Date:

Time:

Received By:

Date:

Time:

Invoice Number

Is sample known to be hazardous? (circle one)

Yes or No

Comments:
 PH + turb @ Marlboro 5/23/22
 X only run flux if it has exceedance